



# Source Water Assessment Program (SWAP) Report For Petersham Sisters of the Assumption

## What is SWAP?

The Source Water Assessment Program (SWAP), established under the federal Safe Drinking Water Act, requires every state to:

- ? Inventory land uses within the recharge areas of all public water supply sources;
- ? Assess the susceptibility of drinking water sources to contamination from these land uses; and
- ? Publicize the results to provide support for improved protection.

## SWAP and Water Quality

Susceptibility of a drinking water source does *not* imply poor water quality. Actual water quality is best reflected by the results of regular water tests.

Water suppliers protect drinking water by monitoring for more than 100 chemicals, treating water supplies, and using source protection measures to ensure that safe water is delivered to the tap.

Prepared by the  
Massachusetts Department of  
Environmental Protection,  
Bureau of Resource Protection,  
Drinking Water Program

Date Prepared:  
January 26, 2001

**Table 1: Public Water System (PWS) Information**

<b>PWS NAME</b>	Petersham Sisters of the Assumption
<b>PWS Address</b>	211 North Main Street
<b>City/Town</b>	Petersham, Massachusetts
<b>PWS ID Number</b>	2234003
<b>Local Contact</b>	Robert Goodfellow
<b>Phone Number</b>	(978) 724-3468

<b>Well Name</b>	<b>Source ID#</b>	<b>Zone I (in feet)</b>	<b>IWPA (in feet)</b>	<b>Source Susceptibility</b>
Well #1	2234003-01G	227	556	Moderate

## Introduction

We are all concerned about the quality of the water we drink. Drinking water wells may be threatened by many potential sources of contamination, including septic systems, road salting, and improper disposal of hazardous materials. Citizens and local officials can work together to better protect these drinking water sources.

### Purpose of this report:

This report is a planning tool to support local and state efforts to improve water supply protection. By identifying land uses within water supply protection areas that may be potential sources of contamination the assessment helps focus protection efforts on appropriate best management practices (BMPs) and drinking water source protection measures. Department of Environmental Protection (DEP) staff are available to provide information about funding and other resources that may be available to your community.

### This report includes:

1. Description of the Water System
2. Discussion of Land Uses within Protection Areas
3. Recommendations for Protection
4. Attachments, including a Map of the Protection Areas

## 1. Description of the Water System

The well for the facility is located near the rear of the building, protected within a pit and covered. The well has a Zone I of 227 feet and an Interim Wellhead Protection Area (IWPA) of 556 feet. The IWPA provides an interim protection area for a water supply well when the actual recharge area has not been delineated. The actual recharge area to the well may be significantly larger or smaller than the IWPA. The well is located in an aquifer with a high vulnerability to contamination due to the absence of hydrogeologic barriers that can prevent contaminant migration. Please refer to the attached map of the Zone I and IWPA. The well serving the facility has no treatment at this time. For current information on monitoring results and treatment and a copy of the most recent Consumer Confidence Report, please contact the Public Water System contact person listed above

### What is a Protection Area?

A well's water supply protection area is the land around the well where protection activities should be focused. Each well has a Zone I protective radius and an Interim Wellhead Protection Area (IWPA).

- **The Zone I** is the area that should be owned or controlled by the water supplier and limited to water supply activities.
- **The IWPA** is the larger area that is likely to contribute water to the well.

In many instances the IWPA does not include the entire land area that could contribute water to the well. Therefore, the well may be susceptible to contamination from activities outside of the IWPA that are not identified in this report.

### What is Susceptibility?

Susceptibility is a measure of a well's potential to become contaminated due to land uses and activities within the Zone I and Interim Wellhead Protection Area (IWPA).

in Table 1. Drinking water monitoring reporting data is also available on the web via EPA's Envirofacts website at [http://www.epa.gov/enviro/html/sdwis/sdwis\\_query.html](http://www.epa.gov/enviro/html/sdwis/sdwis_query.html).

## 2. Discussion of Land Uses in the Protection Areas

There are a number of land uses and activities within the drinking water supply protection areas that are potential sources of contamination.

#### Key issues include:

1. **Inappropriate Activities in Zone Is;**
2. **An Aboveground Storage Tank (AST) With Heating Oil;**
3. **Agricultural land use; and**
4. **Septic system.**

The overall ranking of susceptibility to contamination for the well is Moderate, based on the presence of all moderate threat land use or activity in the IWPA, as seen in Table 2.

1. **Zone I**– Currently, the well does not meet DEP's restrictions, which only allow water supply related activities in Zone Is. The facility's Zone I contains the on-site buildings and access road onto the property. The public water supplier owns and controls all land encompassed by the Zone I. Please note that systems not meeting DEP Zone I requirements must get DEP approval and address Zone I issues prior to increasing water use or modifying systems.

#### Recommendations:

- ✓ Remove all non-water supply activities from the Zone I to comply with DEP's Zone I requirements.
  - ✓ Do not use or store road salt within the Zone I.
2. **Aboveground Storage Tank (AST)** – There are four AST located on cement pads and walled, in the cellar. The ASTs are piped from the top to prevent leakage. The modifications were made a few years ago to incorporate proper containment and safety practices. If managed improperly, Aboveground Storage Tanks can be a potential source contamination due to leaks or spills of the chemicals they store.

#### Recommendations:

- ✓ Any modifications to the AST must be accomplished in a manner consistent with Massachusetts's plumbing, building, and fire code requirements. Consult with the

**Table 2: Table of Activities within the Water Supply Protection Areas**

Potential Contaminant Sources	Zone I	IWPA	Threat	Comments
Driveway	Yes	Yes	Moderate	Limit road salt usage and provide drainage away from wells
Fuel Storage Above Ground	Yes	Yes	Moderate	Tanks are contained
Agricultural land use	No	Yes	Moderate	Fertilizer & Pesticide use
Septic System	No	Yes	Moderate	See septic systems brochure in the appendix
Structures	Yes	Yes	-	Non-water supply structures in Zone I

\* -For more information on Contaminants of Concern associated with individual facility types and land uses please see the SWAP Draft Land Use / Associated Contaminants Matrix on DEP's website - [www.state.ma.us/dep/brp/dws/](http://www.state.ma.us/dep/brp/dws/).

## Glossary

**Zone I:** The area closest to a well; a 100 to 400 foot radius proportional to the well's pumping rate. To determine your Zone I radius, refer to the attached map.

**IWPA:** A 400 foot to ½ mile radius around a public water supply well proportional to its pumping rate; the area DEP recommends for protection in the absence of a defined Zone I. To determine IWPA radius, refer to the attached map.

**Zone II:** The primary recharge area defined by a hydrogeologic study.

**Aquifer:** An underground water-bearing layer of permeable material that will yield water in a usable quantity to a well.

**Hydrogeologic Barrier:** An underground layer of impermeable material that resists penetration by water.

**Recharge Area:** The surface area that contributes water to a well.

local fire department for any additional local code requirements regarding ASTs.

- 3. Agricultural land use** - A farm is located within the IWPA of the well. If improperly stored or applied, the contaminants of concern are pesticides and fertilizers that are applied on the cropland.

**Recommendations:**

- ✓ Consider obtaining a conservation restriction for any agricultural land. Another option is to negotiate a "Memorandum of Understanding" (MOU) with the farmer to refrain from using pesticides and fertilizers and eliminate manure storage within the IWPA.
- ✓ Encourage farmers in the IWPA to seek assistance from the Natural Resource Conservation Service (NRCS) in addressing manure management issues.

- 4. Septic system** – The septic system is located within the IWPA. The on-site sewage treatment is composed of two 15,000 gallon concrete tanks, and is pumped annually. If improperly used or maintained, septic systems are a potential source of contamination in groundwater and the water supply.

**Recommendations:**

- ✓ Septic system components should be located, inspected, and maintained on a regular basis. Refer to the appendices for more information regarding septic systems.
- ✓ Residents and maintenance staff should be trained on proper disposal of spent household chemicals and encouraged to participate in local Household Hazardous waste collections.

Implementing the following recommendations will reduce the system's susceptibility to contamination.

## 3. Protection Recommendations

Implementing protection measures and best management practices (BMPs) will reduce the well's susceptibility to contamination. Sisters of the Assumption should review and adopt the key recommendations above and the following:

### Zone I:

- ✓ Keep non-water supply activities out of the Zone I.
- ✓ Consider well relocation if Zone I threats cannot be mitigated.
- ✓ Since the on-site building, which is in use, lies within the Zone I, use BMPs and restrict activities that could pose a threat to the water supply.

### Training and Education:

- ✓ Train staff on proper hazardous material use, disposal, emergency response, and best management practices; include custodial staff, groundskeepers, certified operator, and food preparation staff. Post labels as appropriate on raw materials and hazardous waste the well and is treated according to DEP guidance.




Figure 1: Example of how a well could become contaminated by different land uses and activities.

### For More Information:

Contact Josephine Yemoh-Ndi in DEP's Worcester Office at (508) 792-7650 x 5030 for more information and for assistance in improving current protection measures.

More information relating to drinking water and source protection is available on the Drinking Water Program web site at:

[www.state.ma.us/dep/brp/dws/](http://www.state.ma.us/dep/brp/dws/)

### Additional Documents:

To help with source protection efforts, more information is available by request or online at [www.state.ma.us/dep/brp/dws/](http://www.state.ma.us/dep/brp/dws/), including:

1. Water Supply Protection Guidance Materials such as model regulations, Best Management Practice information, and general water supply protection information.
2. MA DEP SWAP Strategy
3. Land Use Pollution Potential Matrix
4. Draft Land/Associated Contaminants Matrix

Copies of this assessment have been provided to the public water supplier, town boards, and the local media.

### Facilities Management:

- ✓ Implement standard operating procedures regarding proper storage, use and disposal of hazardous materials. To learn more, see the hazardous materials guidance manual at [www.state.ma.us/dep/bwp/dhm/dhmpubs.html](http://www.state.ma.us/dep/bwp/dhm/dhmpubs.html).
- ✓ Implement Best Management Practices (BMPs) for the use of fertilizer, herbicides and pesticides on facility property.

### Planning:

- ✓ Work with local officials in town to include the facility IWPA in Aquifer Protection District Bylaws and to assist you in improving protection.
- ✓ Have a plan to address short-term water shortages and long-term water demands. Keep the phone number of a bottled water company readily available.
- ✓ Supplement the SWAP assessment with additional local information and incorporate it into water supply educational efforts. Use a land use inventory to assist in setting priorities, focusing inspections, and creating educational activities.

These recommendations are only part of your ongoing local drinking water source protection. Citizens and community officials should use this SWAP report to spur discussion of local drinking water protection measures.

## 4. Attachments

- Map of the Public Water Supply (PWS) Protection Area.
- Recommended Source Protection Measures Factsheet
- Your Septic System Brochure
- Pesticide Use Factsheet